



# PUBLIC WORKS DEPARTMENT

---

CITY OF PORTSMOUTH

680 Peverly Hill Road

Portsmouth N.H. 03801

(603) 427-1530 FAX (603) 427-1539

January 13, 2012

Stephanie Larson  
NHDES  
PO Box 95  
29 Hazen Drive  
Concord, NH 03301

Subject: Daily Maximum Fecal Violations  
NPDES Permit No. NH0090000  
Discharge No. 005A

Dear Ms. Larson:

This is the five-day follow up letter for a daily maximum fecal violation for the Pease Facility. The following conditions occurred:

Date of Sample: 1/8/12

Chlorine Residual before Dechlorination at the time of Sample: 11.4 mg/L

Chlorine Residual after Dechlorination at the time of Sample: 0.02 mg/L

Free Chlorine 0.4 mg/L

Plant Flow at time of Sample: 0.64 MGD

Fecal Results: 17/100ml

Please call if you have any questions or need additional information.

Sincerely,

David S. Allen  
Deputy Director, Public Works

Cc: Joy Hilton, USEPA  
Paula Anania